

September 12, 2013

Town of Dewey Beach
105 Rodney Ave.
Dewey Beach, DE.19971

Re: Special inspections for spray applied fire resistant materials
Hyatt Place at Ruddertowne; 124 Dickinson Street; Dewey Beach, DE

Mr. William Mears,

This letter is in response to a concern brought forth by the Town of Dewey Beach in a memorandum dated 09-12-13. This letter will specifically address the request for a special inspection for spray applied fire resistant materials.

There are no areas of the building that use sprayed fire resistant materials as per 2003 IBC Section 1704.1.

You may be referring to the spray foam insulation on the underside of the first floor slab within the garage. The spray foam is protected with a thermal barrier coating per section 2603.4. The spray foam insulation and the thermal barrier coatings are not subject to special inspections.

Sincerely,



Bruce D. Weinstein, AIA
President
Delaware Architecture License Number: S5-0005956

